

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DTP Certified Lab #104006

Edison Elementary School

205 Melrose Avenue
Westmont, NJ 08108

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 08:40 - 08:59

Date & Time Analyzed: 04/19/2017 12:56 - 14:34


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
EDSN-WC-01-HALL	<2.00	15.5
EDSN-DW-02-HALL1	8.82	15.5
EDSN-SO-02-HALL	6.77	15.5
EDSN-DW-02-HALL2	2.98	15.5
EDSN-NS-03-NUR	<2.00	15.5
EDSN-CS-02-RM103	2.68	15.5
EDSN-WC-02-HALL	<2.00	15.5
EDSN-KC-02-KIT	<2.00	15.5
EDSN-DW-03-HALL1	2.37	15.5
EDSN-SO-03-HALL	8.34	15.5
EDSN-DW-03-HALL2	5.56	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
SJ DEP Certified Lab #08006

Jennings Elementary School

100 East Cedar Avenue
Haddon Twp, NJ 08107

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 09:45 - 09:59

Date & Time Analyzed: 04/19/2017 16:55 - 17:07

Date & Time Analyzed: 04/20/2017 10:08 - 11:04


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
JENN-DW-02-HALL	6.51	15.5
JENN-NS-02-NURSE	4.39	15.5
JENN-WC-03-HALL	<2.00	15.5
JENN-SO-03-HALL	23.8	15.5
JENN-SO-03-BOOK	4.42	15.5
JENN-WC-02-HALL	<2.00	15.5
JENN-CS-02-RM108	<2.00	15.5
JENN-KC-02-KITCH	<2.00	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterfest.com
NJ DEP Certified Lab #080AK6

Stoy Elementary School

206 Briarwood Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 08:05 - 08:23

Date & Time Analyzed: 04/19/2017 11:19 - 12:39


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
STOY-WC-02-HALL	<2.00	15.5
STOY-DW-02-HALL2	<2.00	15.5
STOY-DW-02-HALL1	<2.00	15.5
STOY-DW-02-RM113	<2.00	15.5
STOY-DW-02-112	5.69	15.5
STOY-NS-02-NURSE	3.31	15.5
STOY-KC-02-KIT	<2.00	15.5
STOY-WC-02-STAIR	<2.00	15.5
STOY-TL-01-FAC	<2.00	15.5
STOY-WC-02-HALL2	<2.00	15.5
STOY-WC-02-HALL1	<2.00	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Strawbridge Elementary School

307 Strawbridge Avenue
Westmont, NJ 08108

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 09:10 - 09:33

Date & Time Analyzed: 04/19/2017 14:39 - 06:18


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
STRW-WC-01-HALL	<2.00	15.5
STRW-KC-01-KIT	3.01	15.5
STRW-WC-02-HALL1	<2.00	15.5
STRW-WC-02-HALL2	<2.00	15.5
STRW-DW-02-HALL	<2.00	15.5
STRW-NS-02-NUR	3.30	15.5
STRW-SO-02-NSTRT	9.32	15.5
STRW-TL-02-FAC	<2.00	15.5
STRW-DW-02-RM107	<2.00	15.5
STRW-CS-02-RM106	<2.00	15.5
STRW-DW-02-RM104	<2.00	15.5
STRW-CS-02-RM105	<2.00	15.5
STRW-SO-03-HALL	2.10	15.5
STRW-WC-03-HALL	<2.00	15.5
STRW-TL-03-FAC	3.12	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwater test.com
NJ DEP Certified Lab #18896

Van Sciver Elementary School

625 Rhoads Avenue
Haddonfield, NJ 08033

Results of Lead Analysis


Date & Time Sampled: 04/11/2017 10:21 - 11:08

Date & Time Analyzed: 04/20/2017 13:32 - 15:11

Date & Time Analyzed: 04/21/2017 10:26 - 12:42

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
VANS-DW-RM156	6.13	15.5
VANS-CS-RM156	3.31	15.5
VANS-DW-RM151	4.29	15.5
VANS-CS-RM151	6.48	15.5
VANS-DW-RM154	7.54	15.5
VANS-CS-RM154	<2.00	15.5
VANS-WC-HALL2	<2.00	15.5
VANS-CS-RM139(1)	10.2	15.5
VANS-CS-RM139(2)	13.7	15.5
VANS-CS-RM141	17.4	15.5
VANS-WC-HALL6	<2.00	15.5
VANS-WC-HALL5	<2.00	15.5
VANS-TL-FACUL	2.23	15.5
VANS-WC-HALL1	<2.00	15.5
VANS-SP-NRSRR	<2.00	15.5
VANS-SO-NSTRT	<2.00	15.5
VANS-NS-NURSE	3.19	15.5
VANS-CS-RM105	3.86	15.5
VANS-DW-RM104	3.86	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Van Sciver Elementary School

625 Rhoads Avenue
Haddonfield, NJ 08033

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 10:21 - 11:08

Date & Time Analyzed: 04/20/2017 13:32 - 15:11

Date & Time Analyzed: 04/21/2017 10:26 - 12:42

Sample Location	Sample Result	Action Level
VANS-CS-RM102	4.01	15.5
VANS-DW-RM102	2.81	15.5
VANS-CS-RM101	11.3	15.5
VANS-DW-RM101	2.72	15.5
VANS-DW-RM115	3.40	15.5
VANS-CS-RM115	7.23	15.5
VANS-CS-RM116	5.06	15.5
VANS-CS-RM118	<2.00	15.5
VANS-DW-RM118	33.3	15.5
VANS-CS-RM117	2.87	15.5
VANS-DW-RM117	9.44	15.5
VANS-CS-RM124	<2.00	15.5
VANS-WC-HALL7	<2.00	15.5
VANS-KC-KITCH	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date



South Jersey
Water Test, LLC
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #06166

William G. Rohrer Middle School

101 MacArthur Boulevard
Haddon Township, NJ 08108

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 11:13 - 11:32

Date & Time Analyzed: 04/20/2017 11:42 - 13:27


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MID-WC-01-HALL3	<2.00	15.5
MID-WC-01-HALL4	<2.00	15.5
MID-SO-01-OFFRR	2.07	15.5
MID-KC-01-KITCH	<2.00	15.5
MID-NS-01-NURSE	<2.00	15.5
MID-WC-01-HALL2	<2.00	15.5
MID-CS-01-LFSK1	<2.00	15.5
MID-CS-01-LFSK2	<2.00	15.5
MID-CS-01-LFSK3	<2.00	15.5
MID-CS-01-LFSK4	<2.00	15.5
MID-WC-02-HALL1	<2.00	15.5
MID-TL-02-FACUL	<2.00	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #080306

Haddon Township High School

406 Memorial Avenue
Westmont, NJ 08108

Results of Lead Analysis


Date & Time Sampled: 04/11/2017 06:32 - 07:50

Date & Time Analyzed: 04/18/2017 11:35 - 17:14

Date & Time Analyzed: 04/19/2017 10:59

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
HTHS-SO-01-MAINT	<2.00	15.5
HTHS-SO-01-CUST	2.62	15.5
HTHS-KC-01-KIT3	<2.00	15.5
HTHS-KC-01-KIT4	<2.00	15.5
HTHS-KC-01-KIT5	<2.00	15.5
HTHS-KC-01-KIT1	<2.00	15.5
HTHS-KC-01-KIT2	<2.00	15.5
HTHS-BF-01-CAFÉ	<2.00	15.5
HTHS-WL-01-CAFÉ	<2.00	15.5
HTHS-WC-01-HALL1	<2.00	15.5
HTHS-WC-01-HALL2	<2.00	15.5
HTHS-DW-01-GYMLB	<2.00	15.5
HTHS-WC-01-HALL3	<2.00	15.5
HTHS-HB-01-TRAIN	2.14	15.5
HTHS-IM-01-TRAIN	<2.00	15.5
HTHS-DW-01-BOYLR	<2.00	15.5
HTHS-IM-01-KIT	<2.00	15.5
HTHS-WC-02-HALL5	<2.00	15.5
HTHS-WC-02-HALL4	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Haddon Township High School

406 Memorial Avenue
Westmont, NJ 08108

Results of Lead Analysis


Date & Time Sampled: 04/11/2017 06:32 - 07:50

Date & Time Analyzed: 04/18/2017 11:35 - 17:14

Date & Time Analyzed: 04/19/2017 10:59

Sample Location	Sample Result	Action Level
HTHS-WC-02-HALL2	<2.00	15.5
HTHS-SO-02-MEDIA	<2.00	15.5
HTHS-WC-02-AUDLB	<2.00	15.5
HTHS-WC-02-HALL1	<2.00	15.5
HTHS-SO-02-OFFRR	<2.00	15.5
HTHS-SO-02-ATTEN	<2.00	15.5
HTHS-SO-02-ATTRR	<2.00	15.5
HTHS-DW-02-HALL	11.3	15.5
HTHS-DW-02-NURSE	<2.00	15.5
HTHS-CS-02-FAM1	<2.00	15.5
HTHS-CS-02-FAM2	<2.00	15.5
HTHS-CS-02-FAM3	<2.00	15.5
HTHS-CS-02-FAM4	<2.00	15.5
HTHS-CS-02-FAM5	<2.00	15.5
HTHS-CS-02-FAM6	<2.00	15.5
HTHS-CS-02-FAM7	<2.00	15.5
HTHS-CS-02-FAM8	<2.00	15.5
HTHS-CS-02-FAM9	<2.00	15.5
HTHS-DW-02-GRLLR	<2.00	15.5
HTHS-WC-03-HALL1	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #10006

Haddon Township High School

406 Memorial Avenue
Westmont, NJ 08108

Results of Lead Analysis

Date & Time Sampled: 04/11/2017 06:32 - 07:50

Date & Time Analyzed: 04/18/2017 11:35 - 17:14

Date & Time Analyzed: 04/19/2017 10:59


Sample Location	Sample Result	Action Level
HTHS-WC-03-HALL2	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date